FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 23-03-2015**

1. TESTING OF FINE AGGREGATES:

Sub: Testing of Fine Aggregates.

{Project*: Construction of Senior Citizen Building near Hopcoms at Vidyaranyapura in Ward No. 09 Vidyaranyapura Sub Division (Phase-2).}

Ref.: Letter No. AEE/BBMP/VSD/PR/345/2014-15, dated 18-03-2015

Sample supplied to lab by : Assistant Executive Engineer
Vidyaranyanapura Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: Sri Hemadhri Reddy.

TABLE - 1.1 : SIEVE ANALYSIS :

IS Sieve Size, mm	**Percentage Passing**	Specification as Per IS: 383-1970(Reaffirmed 2002) **Percentage Passing**			Remarks
		Zone-I	**Zone-II**	**Zone -III**	
04.75	97.05	90-100	90-100	90-100	The Sample Conforms to Grading **Zone-II**
02.36	83.75	60-95	75-100	85-100	
01.18	74.00	30-70	55-90	75-100	
600. mic	43.25	15-34	35-59	60-79	
300.mic	18.20	5-20	8-30	12-40	
150.mic	2.85	0-10	0-10	0-10	

TABLE 1.2 ;

Sl No	Test Conducted	Sample	Results	Requirements as Per IS. Specification IS :383-1970 (Reaffirmed 2002)
1	Silt Content	001	1.40 %	Not more than 8%
2.	Specific Gravity	----	2.60	-------

*As furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056,

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ
ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ.

25/3/2015

Dr. MANJESH .L
ME (Civil Engg) Ph D MISTE MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 27-03-2015**

1. TEST REPORT ON CEMENT:

Sub: Testing of 53 Grade Cement Sample (IS 12269-1987).
{Project*: Construction of Senior Citizen Building near Hopcoms at Vidyaranyapura in Ward No. 09 Vidyaranyapura Sub Division (Phase-2).}
Ref.: Letter No. AEE/BBMP/VSD/PR/345/2014-15, dated 18-03-2015
Sample supplied to lab by : Assistant Executive Engineer
Vidyaranyanapura Sub-Division
BBMP, Bangalore.
Name of the Contractor/ Agency*: Sri Hemadhri Reddy.

PHYSICAL TESTS ON CEMENT

Brand* : Birla Super Grade *: 53
Type * : OPC
Date : 19-03-2015 to 26-03-2015

SL No	Name of Test	Results	Requirements as per
		Cement Sample	IS 12269-1987
1.	Initial setting time	**132 min**	Shall not be less than 30 min
2	Final setting time	**240 min**	Shall not be more than 600 min
3	Fineness (by dry sieving on IS 90 micron sieve)	**2.24 %**	Not to exceed 10.0%
4	Soundness test(by Le-Chatelier's method)	**1.48 mm**	Shall not be more than 10 mm
5	Compressive strength a) 3 days (average of three results) b) 7 days (average of three results)	**29.70 N/ Sq mm** **42.90 N/Sq mm**	Shall not be less than 27 N/Sqmm Shall not be less than 37N/Sqmm

*As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056.
e-mail: manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 23-03-2015**

1. TESTING OF COARSE AGGREGATES (40 mm):

Sub: Testing of Coarse Aggregates.

{Project*: Construction of Senior Citizen Building near Hopcoms at Vidyaranyapura in Ward No. 09 Vidyaranyapura Sub Division (Phase-2).}

Ref.: Letter No. AEE/BBMP/VSD/PR/345/2014-15, dated 18-03-2015

Sample supplied to lab by : Assistant Executive Engineer
Vidyaranyanapura Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: Sri Hemadhri Reddy.

Table - 1.1 : SIEVE ANALYSIS :

IS Sieve Size, mm	Percentage passing	Requirements as per IS 383-1970 (Reaffirmed on 2002) % Passing	
	40 mm Sample	*Single size*	*Graded*
40mm	96.10	85-100	95 – 100
20mm	41.60	0 -20	30- 70
10mm	25.70	0 -5	10- 35
4.75mm	Nil	------	0 - 5

TABLE 1 2 :

SL No	Test conducted	Sample No	Results	Requirements as per IS:383-1970 & Test Conforms to IS 2386(Part I to IV) – 1963 (Reaffirmed on 2002)
1.	Flakiness Index	As above	14.95 %	Not to exceed 25 %
2.	Crushing value	----,,----	24.60 %	Not to exceed 45 % for concrete other than for wearing surfaces and 30% for concrete for wearing surfaces

*As furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Inana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರಿಗೆ
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ,
ಯಲಹಂಕ ಕಲಂ,
ಬ. ಬೆ. ಮ. ಕಾ. ಬಂಗಳೂರು-೯೦

23/3/2015
DR. MANJESH .L
ME (Civil Engg). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 23-03-2015**

1. TEST REPORT ON REINFORCEMENT STEEL :

Sub: Testing of Reinforcement Steel of diameter 10mm.
{Project*: Construction of Senior Citizen Building near Hopcoms at Vidyaranyapura in Ward No. 09 Vidyaranyapura Sub Division (Phase-2).}

Ref.: Letter No. AEE/BBMP/VSD/PR/345/2014-15, dated 18-03-2015

Sample supplied to lab by : Assistant Executive Engineer
Vidyaranyanapura Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: Sri Hemadhri Reddy.

TABLE – 1

SL No	Details	For 10 mm	
		Test Results	Req as per IS 1786-2008
01	Observed diameter of bar	**10.0 mm**	10.0 mm
02	Observed Wt/m Length **Kg/m**	**0.620**	0.567
03	Proof stress/Yield stress, fy , **N/mm^2**	**561.0**	500.0
04	Bend/ Re bend Test	**Ok**	---
05	Percentage of Elongation, %	**19.70**	12.00
06	Ultimate Tensile Strength **N/mm^2**	**642.0**	545.0

*As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg .), Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail manjesh[illegible].com

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ,
ಯಲಹಂಕ ವಲಯ,
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-97

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2015-16/ **DATE: 06-04-2015**

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (07days Compressive Strength)
{Project*: Construction of Senior Citizen Building near Hopcoms at Vidyaranyapura in Ward No. 09 Vidyaranyapura Sub Division (Phase-2).}

Ref.: Letter No. AEE/BBMP/VSD/PR/345/2014-15, dated 04-04-2015

Sample supplied to lab by : Assistant Executive Engineer
Vidyaranyanapura Sub-Division
BBMP, Bangalore.

Name of the Contractor/ Agency*: Sri Hemadhri Reddy.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M_{20}

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-03-15	04-04-15	07	22500	370	16.44	**16.14**
	002	"	"	"	"	355	15.77	
	003	"	"	"	"	365	16.22	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering,
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

6/4/2015
Dr. MANJESH .L
ME (Civil Engg .). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail manjeshl@yahoo.com

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ
ಯಲಹಂಕ ವಲಯ,
ಬೃ. ಬೆಂ. ಮ ಸಾ. ಬೆಂಗಳೂರು-97.